



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

***ALL METALS
 Analysis Report**

Submitter Identification Number: 0140035

SALADO WSC
 RHODES, FLETCHER
 PO BOX 128
 SALADO, TX 76571-0128

Date Reported : 04/23/2019
 Report ID# : 20190423141231AE60618

Lab Sample ID# : AE60618 Water Source : Date Collected : 04/01/2019 12:40
 Sample Priority : NORMAL Entry Point(s) : EP004 Date Received : 04/02/2019
 TCEQ ID#(s) : 1915454

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	04/02/2019	BF
pH Check	Completed		EPA 200.2	04/03/2019	BF
Turbidity Screen	Completed		SM 2130B	04/03/2019	BF
Visible Particles	Completed			04/03/2019	BF
Total Hardness as CaCO3 by Calculation	288	mg/L	SM 2340B	04/08/2019	BF
Aluminum ¹	< 0.0200	mg/L	EPA 200.8	04/15/2019	IU
Antimony ¹	< 0.0010	mg/L	EPA 200.8	04/15/2019	IU
Arsenic ¹	< 0.0020	mg/L	EPA 200.8	04/15/2019	IU
Barium ¹	0.0464	mg/L	EPA 200.8	04/15/2019	IU
Beryllium ¹	< 0.00080	mg/L	EPA 200.8	04/15/2019	IU
Cadmium ¹	< 0.0010	mg/L	EPA 200.8	04/15/2019	IU
Calcium	87.9	mg/L	EPA 200.7	04/08/2019	BF
Chromium ¹	< 0.0100	mg/L	EPA 200.8	04/15/2019	IU
Copper ¹	< 0.0020	mg/L	EPA 200.8	04/15/2019	IU
Iron ¹	< 0.010	mg/L	EPA 200.7	04/08/2019	BF
Lead ¹	< 0.0010	mg/L	EPA 200.8	04/15/2019	IU
Magnesium ¹	16.6	mg/L	EPA 200.7	04/08/2019	BF
Manganese ¹	< 0.0010	mg/L	EPA 200.8	04/15/2019	IU
Mercury ¹	< 0.00040	mg/L	EPA 245.1	04/09/2019	BF
Nickel ¹	0.0019	mg/L	EPA 200.8	04/15/2019	IU
Potassium ¹	1.25	mg/L	EPA 200.7	04/08/2019	BF
Selenium ¹	< 0.0030	mg/L	EPA 200.8	04/15/2019	IU
Silver ¹	< 0.0100	mg/L	EPA 200.8	04/15/2019	IU
Sodium ¹	14.3	mg/L	EPA 200.7	04/08/2019	BF
Thallium ¹	< 0.00040	mg/L	EPA 200.8	04/15/2019	IU
Zinc ¹	0.0820	mg/L	EPA 200.8	04/15/2019	IU

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 04/18/2019